



MUNICIPAL CORPORATION CHANDIGARH  
Public Health Laboratory at Water Works Sector 39.

TEST - REPORT

Not for legal use

Ref. No. & Date

: - No. GMHS/41A/2023/493 Dated 01.08.2023

Issued to

: - ✓ The Headmistress,  
Govt. Model High School,  
Sector - 41- A, Chandigarh ,  
Approximate 1200 ml.  
03.08.2023  
Sample collected by Laboratory Staff.  
Sample filled in P.P. and Glass Bottle.  
from School Tap of Govt. Model High School,  
Sector - 41- A, Chandigarh ,

Quantity of sample

Date of Collection

Client reference

Packing of sample

Source of sample


S. No.	Examination	Quality Standard	Units	Results
1.	Turbidity	<1.0	N.T.U	0.7
2.	pH	7.0-8.5	----	7.79
3.	Residual Chlorine	0.2 - 0.4	mg/L	0.3
4.	Total Alkalinity (as CaCO <sub>3</sub> )	200	-do-	76
5.	Total Hardness (as CaCO <sub>3</sub> )	200	-do-	68
6.	Chlorides (as Cl)	200	-do-	04
7.	Free & Saline Ammonia	Nil	-do-	Nil
8.	Total Dissolved Solids	500	-do-	119
9	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received vide Receipt No.08/2023-24/147563, dated 01.08.2023, Amount Rs.3300/-.

Note:- Water is fit for drinking.

Lab. No. MCPHL/23/ 3351

Dated: - 05.08.2023


  
Chemist,  
MCPH Laboratory,  
Chandigarh


  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No. 1,  
Chandigarh

Dated:-

Endst No. MCPHL/23/

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for information Please.

  
Chemist  
MCPH Laboratory  
Chandigarh

  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No. 1,  
Chandigarh